



Test Report issued under
the responsibility of:



TEST REPORT
IEC 60950-1
Information technology equipment - Safety -
Part 1: General requirements

Report Reference No : E141988-A33-CB-4

Date of issue : 2016-06-30

Total number of pages : 55

CB Testing Laboratory : UL Japan, Inc.

Address : 4383-326 Asama-cho, Ise-shi, Mie, 516-0021, Japan

Applicant's name : KAGA COMPONENTS CO LTD

Address : 20 KANDAMATSUNAGACHO

CHIYODA-KU

TOKYO 101-0023 JAPAN

Test specification:

Standard : IEC 60950-1:2005 (Second Edition); Am1:2009 + Am2:2013

Test procedure : CB Scheme

Non-standard test method : N/A

Test Report Form No. : IEC60950_1F

Test Report Form originator : SGS Fimko Ltd

Master TRF : Dated 2014-02

Copyright © 2014 Worldwide System for Conformity Testing and Certification of Electrotechnical Equipment and Components (IECEE), Geneva, Switzerland. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.



If this test Report is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer

The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Test item description	Power Supply for building-in, switch mode type
Trade Mark	TRACO POWER
Manufacturer	TRACO ELECTRONIC AG SIHLBRUGGSTRASSE 111 CH-6340 BAAR SWITZERLAND
Model/Type reference	TMS06105, TMS06112, TMS06115, TMS06124, TMS06212, TMS06215
Ratings	TMS06105 Input: 115-230 Vac, 50/60 Hz, 0.11-0.07 A Output: 5 Vdc, 1.2 A TMS06112 Input: 115-230 Vac, 50/60 Hz, 0.11-0.07 A Output: 12 Vdc, 0.5 A TMS06115 Input: 115-230 Vac, 50/60 Hz, 0.11-0.07 A Output: 15 Vdc, 0.4 A TMS06124 Input: 115-230 Vac, 50/60 Hz, 0.11-0.07 A Output: 24 Vdc, 0.25 A TMS06212 Input: 115-230 Vac, 50/60 Hz, 0.12-0.07 A Output: ± 12 Vdc, 0.25 A TMS06215 Input: 115-230 Vac, 50/60 Hz, 0.12-0.07 A Output: ± 15 Vdc, 0.2 A

Testing procedure and testing location:	
<input checked="" type="checkbox"/> CB Testing Laboratory	Testing location / address: UL Japan, Inc. 4383-326 Asama-cho, Ise-shi, Mie, 516-0021, Japan
<input type="checkbox"/> Associated CB Test Laboratory	Testing location / address:
	Tested by (name + signature): Toshiyuki Suzuki, Project Handler 
	Approved by (name + signature).....: Masatomo Takiyama, Reviewer 
<input type="checkbox"/> Testing Procedure: TMP/CTF Stage 1	
	Testing location / address:
	Tested by (name + signature): _____
	Approved by (name + signature).....: _____
<input type="checkbox"/> Testing Procedure: WMT/CTF Stage 2	
	Testing location / address:
	Tested by (name + signature): _____
	Witnessed by (name + signature) ...: _____
	Approved by (name + signature).....: _____
<input type="checkbox"/> Testing Procedure: SMT/CTF Stage 3 or 4	
	Testing location / address:
	Tested by (name + signature): _____
	Approved by (name + signature).....: _____
	Supervised by (name + signature) ..: _____
<input type="checkbox"/> Testing Procedure: RMT	
	Testing location / address:
	Tested by (name + signature): _____
	Approved by (name + signature).....: _____
	Supervised by (name + signature) ..: _____

List of Attachments

National Differences (18 pages)

Enclosures (62 pages)

Summary Of Testing

Unless otherwise indicated, all tests were conducted at UL Japan, Inc. 4383-326 Asama-cho, Ise-shi, Mie, 516-0021, Japan.

Tests performed (name of test and test clause)	Testing location / Comments
Input: Single-Phase (1.6.2)	

Durability of Marking (1.7.11)
Energy Hazard Measurements (2.1.1.5, 2.1.2, 1.2.8.10)
Capacitance Discharge (2.1.1.7)
SELV Reliability Test Including Hazardous Voltage
Measurements (2.2.2, 2.2.3, 2.2.4, Part 22 6.1)
Humidity (2.9.1, 2.9.2, 5.2.2)
Determination of Working Voltage; Working Voltage
Measurement (2.10.2)
Transformer and Wire /Insulation Electric Strength
(2.10.5.13)
Heating (4.5.1, 1.4.12, 1.4.13)
Ball Pressure (4.5.5, 4.5)
Touch Current (Single-Phase; TN/TT System) (5.1, Annex
D)
Electric Strength (5.2.2)
Component Failure (5.3.1, 5.3.4, 5.3.7)
Abnormal Operation (5.3.1 - 5.3.9)
Power Supply Output Short-Circuit/Overload (5.3.7)

Summary of Compliance with National Differences:

Countries outside the CB Scheme membership may also accept this report.

List of countries addressed: DE, DK, EU, FI, GB, KR, SE, SI

The product fulfills the requirements of: EN 60950-1:2006 + A1:2010 + A11:2009 + A12:2011 + A2:2013

Copy of Marking Plate

The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCBs that own these marks.



Test item particulars :

Equipment mobility	for building-in (component-type)
Connection to the mains	Not connected to the mains directly.
Operating condition	continuous
Access location	N/A
Over voltage category (OVC)	OVC II
Mains supply tolerance (%) or absolute mains supply values	+10%, -10%
Tested for IT power systems	Considered in the end product.
IT testing, phase-phase voltage (V)	Considered in the end product.
Class of equipment	Class I (earthed)
Considered current rating of protective device as part of the building installation (A)	16 A (branch circuit)
Pollution degree (PD)	PD 2
IP protection class	IP X0
Altitude of operation (m)	less than 2000 m
Altitude of test laboratory (m)	approximately 10 to 20 m
Mass of equipment (kg)	approximately 30 g

Possible test case verdicts:

- test case does not apply to the test object : N / A
- test object does meet the requirement : P(Pass)
- test object does not meet the requirement : F(Fail)

Testing:

Date(s) of receipt of test item	2006-10-19, 2006-10-31, 2006-11-16, 2007-02-05, 2010-10-28
Date(s) of Performance of tests	2007-02-07, 2007-02-16, 2010-10-29

General remarks:

"(see Enclosure #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a point is used as the decimal separator.

Manufacturer's Declaration per Sub Clause 4.2.5 of IEC 60950-1:

Yes

The application for obtaining a CB Test Certificate includes more than one factory and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided

When differences exist, they shall be identified in the General Product Information section.

Name and address of Factory(ies):

KAGA COMPONENTS CO LTD
 NIIGATA PLANT
 1194-3 MOKKOUSHI-MACHI, HIGASHI-KU, NIIGATA-SHI,
 NIIGATA-KEN 950-0807 JAPAN

DONGGUAN POWERTEK ELECTRONICS CO LTD
CHILING INDUSTRIAL ESTATE, HOUJIE ZHEN, DONGGUAN
CITY, GUANGDONG, CHINA

GENERAL PRODUCT INFORMATION:

Report Summary

All applicable tests according to the referenced standard(s) have been carried out.

Product Description

These models covered in this report were component power supply intended for use in Information Technology Equipment.

Model Differences

Model TMS061xx is single(+) output DC power supply unit.

Model TMS062xx is dual(\pm) output DC power supply unit.

The "xx" in model designation indicate output voltage of power supply unit.

Each model is identical, except for output ratings, minor differences in the secondary circuit components and the number of turns of secondary winding in the Transformer (T1).

Additional Information

This report is a reissue of CBTR Ref. No. E141988-A33-CB-3, CB Test Certificate Ref. Nos. JP-10743-UL and JP-10744-UL due to the following modifications:

1. Upgrade of standard from IEC 60950-1, 2nd edition + Amendment 1 to IEC60950-1, 2nd edition + Amendment 1 + Amendment 2.
2. Deletion of Models KB6-05S, KB6-12S, KB6-15S, KB6-24S, KB6-122D and KB6-153D.
3. Deletion of Manufacturer "KAGA COMPONENTS CO LTD".
4. Update of address of Applicant and Manufacturer.
5. Change of Manufacturer of X-Capacitor (C1) from "Panasonic Electronic Devices Japan Co., Ltd." to "Panasonic Corp. Automotive & Ind. System Company Device Solutions Business Division.".
6. The word "Various" was changed to "Interchangeable" in list of critical components.

Based on the previously conducted testing and the review of product technical documentation including photos, schematics, wiring diagrams and similar, it has been determined that the product continues to comply with the standard.

Maximum normal load: Rated output load.

Technical Considerations

- The product was submitted and evaluated for use at the maximum ambient temperature (Tma) permitted by the manufacturer's specification of: 40 °C
- The product is intended for use on the following power systems: TN
- The product was investigated to the following additional standards: EN 60950-1:2006 + A11:2009 + A1:2010 + A12:2011 + A2:2013 (which includes all European national differences, including those

specified in this test report).

Engineering Conditions of Acceptability

When installed in an end-product, consideration must be given to the following:

- The end-product Electric Strength Test is to be based upon a maximum working voltage of: Primary-Earthed Dead Metal: 249 V rms, 524 V pk, Primary-SELV: 249 V rms, 524 V pk for Models TMS06105, TMS06112, TMS06115, Primary-Earthed Dead Metal: 246 V rms, 536 V pk, Primary-SELV: 258 V rms, 548 V pk for Models TMS06124, TMS06212, TMS06215.
- The following secondary output circuits are ELV: All model's output circuits
- The following secondary output circuits are at non-hazardous energy levels: All model's output circuits
- The power supply terminals and/or connectors are: Suitable for factory wiring only
- The maximum investigated branch circuit rating is: 16 A
- The investigated Pollution Degree is: 2
- Proper bonding to the end-product main protective earthing termination is: Required
- An investigation of the protective bonding terminals has: Not been conducted
- The following magnetic devices (e.g. transformers or inductor) are provided with an OBJ2 insulation system with the indicated rating greater than Class A (105°C): T1 (Class B)
- The following end-product enclosures are required: Fire, Electrical
- A suitable disconnect device shall be provided in the end product. --
- A suitable protective device (overcurrent protection) shall be provided in the end product. --
- The evaluation of IT power systems shall be conducted in the end product. --

Abbreviations used in the report:

- normal condition	N.C.	- single fault condition	S.F.C
- operational insulation	OP	- basic insulation	BI
- basic insulation between parts of opposite polarity:	BOP	- supplementary insulation	SI
- double insulation	DI	- reinforced insulation	RI

Indicate used abbreviations (if any)