

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Power Supply for DIN rail mounting

Name and address of the applicant

Traco Power Solutions Ltd.
Whitemill Industrial Estate Wexford, White Mill Road,
Y35 YH66, Ireland

Name and address of the manufacturer

Traco Power Solutions Ltd.
Whitemill Industrial Estate Wexford, White Mill Road,
Y35 YH66, Ireland

Name and address of the factory

Traco Power Solutions Ltd.
Whitemill Industrial Estate Wexford, White Mill Road,
Y35 YH66, Ireland*Note: When more than one factory, please report on page 2*☐ Additional Information on page 2

Ratings and principal characteristics

See page 2

Trademark / Brand (if any)

TRACO POWER

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See page 2

Additional information (if necessary may also be reported on page 2)

Additionally evaluated to EN 61010-1:2010 + A1:2019 and EN IEC 61010-2-201:2018; National Differences specified in the CB Test Reports.

☒ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61010-1:2010 + A1:2016
IEC 61010-2-201:2017

As shown in the Test Report Ref. No. which forms part of this Certificate

T223-0814/20, T223-0815/20 (2020-12-14)

This CB Test Certificate is issued by the National Certification Body

SIQ Ljubljana, Mašera-Spasičeva ulica 10, SI-1000 Ljubljana, Slovenia
T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si

SIQ Ljubljana is accredited by Slovenian Accreditation with accreditation number CP-001 in the field of certification of products, processes and services.

Date: 2020-12-14

Signature: Bojan Pečavar



Model / Type Ref., Ratings and principal characteristics:

TRACO POWER model reference	Custom model reference	Input Ratings			Output Ratings	
		Input voltage (Vac)	Input current (A)	Frequency (Hz)	Output V (VDC)	Output current (A)
TBL 015-105	015PSL181	100-240	0,33-0,19	50/60	5	2,4
TBL 015-112	015PSL182	100-240	0,38-0,24	50/60	12	1,25
TBL 015-124	015PSL184	100-240	0,38-0,24	50/60	24	0,63
TBL 030-112	030PSL182	100-240	0,9-0,5	50/60	12	2,5
TBL 030-124	030PSL184	100-240	0,9-0,5	50/60	24	1,25
TBL 060-112	060PSL182	100-240	1,3-0,8	50/60	12	4,5
TBL 060-124	060PSL184	100-240	1,4-0,9	50/60	24	2,5
TBL 060-124BC	060PSL184BC	100-120 / 220-240	1,4/0,7	50/60	24* (27,6)	2,5 (60W) 2,17 (60W)
TBL 090-112	090PSL182	100-240	1,75-1,0	50/60	12	6
TBL 090-124	090PSL184	100-240	2,2-1,2	50/60	24	3,75
TBL 150-112	150PSL182	100-120 / 220-240	3,2/1,5	50/60	12	10
TBL 150-124	150PSL184	100-120 / 220-240	4,0/1,5	50/60	24	6,25

* 24VDC is rated voltage however when unit operates as a charger output voltage is between 26 and 29,5Vdc and output power is limited to 60W.

Models can be additionally marked with xxaaaaaa, where "x" or "a" can be any alphanumeric, blank or dash, no impact on safety.

Additional information (if necessary)

Date: 2020-12-14

Signature: Bojan Pečavar

