

TRACO POWER

Model: TCL 240-124

EMC – Test Report

EUT: TRACO POWER Model: TCL 240-124

Serial No.: Test Unit 1: 31319786289
Test Unit 2: 31244690081
Test Unit 3: 31319786161

Manufacturer No.: 240PSM184

Manufacturer: Convertec Ltd.
Whitemill Industrial Estate
Wexford
Republic of Ireland

Tester: Gunnar Tapper, Convertec

Date: 05/11/2013

It should be noted, that combining two or more CE compliant finished appliances does not automatically produce a compliant system. The manufacturer of an apparatus or a fixed installation as defined in the “Guide for the EMC Directive 2004/108EC, 21. May 2007” is responsible for the EMC-compliance of the final apparatus.

Table of Contents

| | |
|---|----|
| 1. Conducted Emissions Measurement at Mains Terminals..... | 4 |
| 1.1. Test Setup | 4 |
| 1.2. Conducted Emissions Test Results (Mains Terminals)..... | 5 |
| 2. Radiated Emissions Measurements | 7 |
| 2.1. Test Setup | 8 |
| 2.2. Radiated Emissions Test Results | 9 |
| 3. Harmonic Current Emissions Measurement at Mains Terminal | 10 |
| 3.1. Test Setup: | 10 |
| 3.2. Harmonic Current Emissions Test Results | 11 |
| 4. Electrostatic Discharge Immunity Test | 13 |
| 4.1. Test Set-Up:..... | 13 |
| 4.2. Electrostatic Discharge Immunity Test Results..... | 14 |
| 5. Surge Voltage Immunity Test..... | 15 |
| 5.1. Test Setup | 15 |
| 5.2. Surge Voltage Immunity Test Results | 16 |
| 6. Fast Transient Voltage Immunity Test (Burst)..... | 17 |
| 6.1. Test Setup | 17 |
| 6.2. Fast Transient Voltage (Burst) Test Results. | 18 |
| 7. Voltage Dips and Short Interruptions Test at AC Input Terminals..... | 19 |
| 7.1. Test Setup | 20 |
| 7.2. Voltage Dips & Short Interruptions Results (Classifications) | 20 |
| 8. Conducted RF Immunity Test at AC Mains Terminals..... | 22 |
| 8.1. Test Setup | 22 |
| 8.2. Conducted RF Immunity Test Results | 23 |
| 9. Conducted RF Immunity Test at DC Output Terminals..... | 24 |
| 9.1. Test Setup: | 24 |
| 9.2. Conducted RF Immunity Test Results | 25 |
| 10. Radiated RF Immunity Test..... | 26 |
| 10.1. Test Setup | 26 |
| 10.2. Radiated RF Immunity Test Results | 27 |
| 11. Power Frequency Magnetic Field Immunity Test | 28 |
| 11.1. Test Setup | 28 |
| 11.2. Power Frequency Magnetic Field Immunity Test Results..... | 29 |
| 12. Voltage Sag Immunity Test (Semi F47) | 31 |
| 12.1. Test Setup | 31 |
| 12.2. Voltage Sag Immunity test Results (Semi F47) | 32 |
| 13. Summary..... | 36 |

14. List of Equipment Used:38

1. Conducted Emissions Measurement at Mains Terminals

Equipment under Test: TCL 240-124
EUT Serial No.: 31244690081
Customer Spec: CS-240PSM184.doc
Date: 27/06/2013
Standards: IEC61000-6-3: 2011 referring to CISPR 16-2-1: 2005

Notes:

- EUT tested under normal operating conditions of 230V 50Hz input at full load (24V/10A Resistive).
- Emissions measured using Agilent E7402A EMC Analyzer and PMM LISN L2-16
- Tested to IEC 61000-6-3:Ed 2.1 Class B limits
- Transient limiter used to protect Agilent E7402A, with appropriate correction factors applied
- Tests carried out in a shielded room

1.1. Test Setup

Test Equipment Settings:

| Start Freq. | Stop Freq. | Pk Time | Qpk Time | Avg Time |
|-------------|------------|---------|----------|----------|
| 150kHz | 30MHz | 200ms | 200ms | 200ms |


Test Setup:



1.2. Conducted Emissions Test Results (Mains Terminals)

L1 and L2

dBuV



27/06/2013 08:59:55

(Start = 0.15, Stop = 30.00) MHz

Measurement-List

| Frequency | Peak | Avg | QP | Delta Pk-QP Limit | Delta Avg-Avg Limit | Delta QP-QP Limit | Trace Name |
|-----------|------|------|------|-------------------|---------------------|-------------------|--------------------------------|
| MHz | dBuV | dBuV | dBuV | dB | dB | dB | |
| 0.149 | 60.3 | 26.7 | 52.4 | | | | TCL240-124 SN31244690081 230L1 |
| 0.266 | 54.9 | 42.9 | 51.4 | -6.3 | -8.4 | -9.8 | TCL240-124 SN31244690081 230L1 |
| 0.467 | 53.3 | 30.2 | 45.8 | -3.3 | -16.4 | -10.7 | TCL240-124 SN31244690081 230L1 |
| 0.734 | 50.8 | 26.1 | 43.1 | -5.2 | -19.9 | -12.9 | TCL240-124 SN31244690081 230L1 |
| 3.072 | 46.2 | 25.1 | 42.3 | -9.8 | -20.9 | -13.7 | TCL240-124 SN31244690081 230L1 |
| 4.872 | 52.7 | 35.1 | 49.9 | -3.3 | -10.9 | -6.1 | TCL240-124 SN31244690081 230L1 |
| 0.268 | 55.6 | 41.8 | 53.0 | -5.6 | -9.4 | -8.2 | TCL240-124 SN31244690081 230L2 |
| 0.331 | 55.3 | 42.0 | 52.1 | -4.1 | -7.4 | -7.4 | TCL240-124 SN31244690081 230L2 |
| 0.469 | 53.7 | 29.9 | 46.5 | -2.8 | -16.6 | -10.0 | TCL240-124 SN31244690081 230L2 |
| 0.734 | 51.2 | 25.9 | 43.0 | -4.8 | -20.1 | -13.0 | TCL240-124 SN31244690081 230L2 |
| 0.930 | 48.3 | 28.1 | 42.1 | -7.7 | -17.9 | -13.9 | TCL240-124 SN31244690081 230L2 |
| 1.133 | 46.0 | 27.7 | 40.6 | -10.0 | -18.3 | -15.4 | TCL240-124 SN31244690081 230L2 |

Table 1 - average and quasi peak measurements of the 020PSM184

Remarks:

The orange graph represents peak measurements of line 1 and the green graph represents peak measurements of line 2. Quasi peak and average measurements are measured if the peak measurement is above the relevant limit. See Table 1.

PASS

Environmental conditions

Temperature: 15-30°C

Humidity: 30-60%

Air Pressure: 860-1060 hPa

Environmental conditions during the test:

kept

not kept

2. Radiated Emissions Measurements

Equipment under Test: TCL 240-124
EUT Serial No.: 31244690081
Customer Spec: CS-240PSM184.doc
Date: 27/06/2013
Standards: IEC61000-6-3: 2011 referring to CISPR 16-2-3: 2003

For an apparatus to comply with EMC radiated emissions requirements as set down in CISPR 16-2-3, free field measurements need to be performed. A test method similar to that described in IEC61204-3 (for low-voltage power supplies) section 6.4.2 shall be used here instead of free field measurements. This test is designed to give a good indication of whether an EUT will pass free field measurements or not. The absorber clamp used in this method is replaced by a Fischer high frequency current probe (Model: F-33-1). The limits used are set by comparison with open field measurements and are compensated by 20dB per frequency decade. Two limit lines are indicated; Fis_a and Fis_b, and the results may be interpreted as follows:

- Below limit line Fis_b: Limits are kept
- Below limit line Fis_a: Limits probably kept
- Above limit line Fis_a: Limits most likely not kept

Final Compliance can only be established by free field measurements in accordance to the relevant standard applicable to the apparatus or enclosure in which the power supply is used

Notes:

- EUT tested under normal operating conditions of 230V 50Hz input at full load (24V/10A Resistive).
- Emissions measured using receiver Agilent E7402A and FCC RF current probe
- RF current probe kept a distance of 10cm from input/output
- Tests carried out in shielded room
- Tested to IEC 61000-6-3:Ed 2.1 Class B limits

2.1. Test Setup





Figure 1. Test set-up for measurement of disturbance power similar to IEC61204-3

Test Equipment Settings:


| Start Freq. | Stop Freq. | Pk Time |
|-------------|------------|---------|
| 30MHz | 300MHz | 200ms |

Test Setup: The following shows the setup used for input lines, the setup used for the output lines is the same with the clamp on the input lines.



2.2. Radiated Emissions Test Results

Input Lines and Output Lines:



PASS

Environmental conditions

Temperature: 15-30°C
 Humidity: 30-60%
 Air Pressure: 860-1060 hPa
 Environmental conditions during the test:

kept
 not kept


3. Harmonic Current Emissions Measurement at Mains Terminal

Equipment under Test: TCL 240-124
EUT Serial No.: 31319786289
Customer Spec: CS-240PSM184.doc
Date: 19/08/2013
Standards: IEC61000-6-3: 2006 referring to IEC 61000-3-2: 2005


Notes:

- EUT tested under normal operating conditions of 230V 50Hz input at full load (12V, 10A Resistive).
- EUT powered by low-distortion AC Voltage Source, TTI AC-1000
- Harmonic Limits measured using LMG 95 Power Meter
- Tested to IEC61000-3-2 Table 1 Class A

3.1. Test Setup:



3.2. Harmonic Current Emissions Test Results



| Harmonic | Current (A) | Limit (A) | Harmonic | Current (A) | Limit (A) |
|----------|-------------|-----------|----------|-------------|-----------|
| 0 | 0.004111 | | 20 | 0.000926 | 0.092000 |
| 1 | 1.092490 | | 21 | 0.018938 | 0.107143 |
| 2 | 0.007212 | 1.080000 | 22 | 0.000766 | 0.083636 |
| 3 | 0.978341 | 2.300000 | 23 | 0.026545 | 0.097826 |
| 4 | 0.006018 | 0.430000 | 24 | 0.000651 | 0.076667 |
| 5 | 0.770049 | 1.140000 | 25 | 0.030173 | 0.090000 |
| 6 | 0.004481 | 0.300000 | 26 | 0.000486 | 0.070769 |
| 7 | 0.523625 | 0.770000 | 27 | 0.028337 | 0.083333 |
| 8 | 0.002831 | 0.230000 | 28 | 0.000439 | 0.065714 |
| 9 | 0.297837 | 0.400000 | 29 | 0.023066 | 0.077586 |
| 10 | 0.001637 | 0.184000 | 30 | 0.000348 | 0.061333 |
| 11 | 0.134904 | 0.330000 | 31 | 0.018724 | 0.072581 |
| 12 | 0.001088 | 0.153333 | 32 | 0.000372 | 0.057500 |
| 13 | 0.065201 | 0.210000 | 33 | 0.016934 | 0.068182 |
| 14 | 0.001099 | 0.131429 | 34 | 0.000307 | 0.054118 |
| 15 | 0.058855 | 0.150000 | 35 | 0.014701 | 0.064286 |
| 16 | 0.001137 | 0.115000 | 36 | 0.000258 | 0.051111 |
| 17 | 0.045042 | 0.132353 | 37 | 0.010108 | 0.060811 |
| 18 | 0.001037 | 0.102222 | 38 | 0.000134 | 0.048421 |
| 19 | 0.024335 | 0.118421 | 39 | 0.005693 | 0.057692 |

PASS

Environmental conditions

Temperature: 15-30°C

Humidity: 30-60%

Air Pressure: 860-1060 hPa

Environmental conditions during the test:

kept

not kept


4. Electrostatic Discharge Immunity Test

Equipment under Test: TCL 240-124
EUT Serial No.: 31319786289
Customer Spec: CS-240PSM184.doc
Date: 06/08/2013
Standards: IEC61000-6-2: 2005 referring to IEC 61000-4-2: 2000

Notes:

- EUT tested under normal operating conditions of 230V 50Hz input at full load (24V/10A Resistive).
- Since the EUT output is isolated from earth, a 470K HV resistor was placed between output and Earth to provide a discharge path between spikes
- Contact discharge tests shall be applied to all areas exposed to the end user under final installation using ESD gun SESD 200
- Test voltage shall be increased from 2kV up to the max 8kV/4kV (air/contact) as required by the standard IEC/EN 61000-4-2
- At least 10 discharges were applied per test point (in both polarities)
- A time interval between discharges of a least 1s was used
- The ESD generator was held perpendicular to the test point wherever possible for repeatability of results
- In the case of air discharges, the trigger is engaged at about 20cm and the tester is moved quickly toward the test point until a spark occurs and trigger is released

4.1. Test Set-Up:



4.2. Electrostatic Discharge Immunity Test Results

All exposed metal screw heads and ground planes were tested as contact test points and also as air test points.

The connector pins and all vents and inlets were also tested as air test points.

| | Contact Test points: | Air Test points: |
|-----|----------------------|------------------|
| EUT | PASS | PASS |

Conclusion:

EUT still functions as expected after tests therefore are in accordance with IEC61000-4-2

PASS

Environmental conditions

Temperature: 15-30°C

Humidity: 30-60%

Air Pressure: 860-1060 hPa

Environmental conditions during the test:

kept

not kept


5. Surge Voltage Immunity Test

Equipment under Test: TCL 240-124
EUT Serial No.: 31244690081
Customer Spec: CS-240PSM184.doc
Date: 25/06/2013
Standards: IEC61000-6-2: 2005 referring to IEC 61000-4-5: 2005

Notes:

- EUT tested under normal operating conditions of 230V 50Hz input at full load (24V /10A Resistive).
- Used Haefely Surge generator PSURGE 4010
- Voltage test level: AC port Line-Line +/- 1kV, AC port Line-Earth +/- 2kV (installation class 3)
- DC ports Line-Line & DC ports Line-Earth +/-0,5kV & Signal Ports Line-Earth +/- 1kV (Not tested due to lack of suitable equipment)
- No. of Surges per set: 5 tests Positive and 5 tests Negative
- Interval Between Surges: 10s

5.1. Test Setup



5.2. Surge Voltage Immunity Test Results

| | L+VE to L-VE | L+VE to PE | L-VE to PE |
|-----|--------------|------------|------------|
| EUT | PASS | PASS | PASS |

Conclusion:

Meets Classification B as required per Table 4, IEC 61000-6-2

PASS

Environmental conditions

Temperature: 15-30°C

Humidity: 30-60%

Air Pressure: 860-1060 hPa

Environmental conditions during the test:

kept

not kept

6. Fast Transient Voltage Immunity Test (Burst)

Equipment under Test: TCL 240-124
EUT Serial No.: 31319786289
Customer Spec: CS-240PSM184.doc
Date: 06/08/2013
Standard: IEC61000-6-2: 2005 referring to IEC 61000-4-4: 2004

Notes:

- EUT tested under normal operating conditions of 230V 50Hz input at full load (24V/10A Resistive).
- Units tested to IEC61000-4-4 test level 3
- Used Haefely Burst tester PEFT 4010
- AC & DC Power ports Voltage test level: +/-2kV
- Signal Ports Voltage test level: +/-1kV
- Burst Duration: 0.75ms
- Spike frequency: 100kHz
- Burst Period: 300ms
- Individual test time: 1 min
- Polarity: Positive and Negative

The Output lines and Signal lines were tested to the above mentioned limits with Haefely coupling capacitor IP4A

6.1. Test Setup



6.2. Fast Transient Voltage (Burst) Test Results.

| EUT: | +VE-G | -VE-G | PE-G | +VE, -VE-G | +VE,PE-G | -VE,PE-G | +VE, -VE,PE-G | Outputs -G | Signals -G |
|----------|-------|-------|------|------------|----------|----------|---------------|------------|------------|
| Positive | PASS | PASS | PASS | PASS | PASS | PASS | PASS | PASS | PASS |
| Negative | PASS | PASS | PASS | PASS | PASS | PASS | PASS | PASS | PASS |

Conclusion:

Meets Classification B as required per Table 2, 3 & 4, IEC 61000-6-2

PASS

Environmental conditions

Temperature: 15-30°C

Humidity: 30-60%

Air Pressure: 860-1060 hPa

Environmental conditions during the test:

kept

not kept


7. Voltage Dips and Short Interruptions Test at AC Input Terminals

Equipment under Test: TCL 240-124
EUT Serial No.: 31319786161
Customer Spec: CS-240PSM184.doc
Date: 04/11/2013
Standard: IEC61000-6-2:2005 referring to IEC 61000-4-11:2004

Notes:

- EUT tested at full load (24V/10A Resistive).
- Test carried out using 2 Variacs and dropout simulator NSG 1003
- Tested according to class 3 IEC61000-4-11 (as per Annex B)
- Unit tested with the nominal low line and high line input voltage (115V/230V) in accordance with IEC61000-4-11 section 5
- Interval between dropouts and short interruptions was 10s
- Phase angle was set to 0°, 90°, 180°, 270° for each voltage level tested
- Voltage Dips were tested from 100%-80% for 250 Mains cycles in accordance with IEC61000-4-11 table 1
- Voltage Dips were tested from 100%-70% for 25 Mains cycles in accordance with IEC61000-4-11 table 1
- Voltage Dips were tested from 100%-40% for 10 Mains cycles in accordance with IEC61000-4-11 table 1
- Voltage Dips were tested from 100%-0% for 1 Mains cycle in accordance with IEC61000-4-11 table 1
- Voltage Dips were tested from 100%-0% for ½ Mains cycle in accordance with IEC61000-4-11 table 1
- 3 Voltage dips and 3 Short Interruptions were carried out per test
- Short interruptions tests were carried out at 100% to 0% for each duration 0.1s, 0.2s, 0.5s, 1s, 2s, and 5s. Voltage interruption of 250 cycles @ 50Hz (5s) required for Class 3, IEC61000-4-11 table 2.
- Short interruptions were done at worst case 0° phase angle
- Classification of performance in accordance to IEC61000-4-11 Section 9.

7.1. Test Setup



7.2. Voltage Dips & Short Interruptions Results (Classifications)

| Voltage Dips Test Results | | | | | | |
|---------------------------|--------|-------------|-----|------|------|---------------------|
| 230VAC | | | | | | |
| Input Voltage | | Phase Angle | | | | Mains Cycles (50Hz) |
| | | 0° | 90° | 180° | 270° | |
| 100% - 80% | 184VAC | A | A | A | A | 250 |
| 100% - 70% | 161VAC | A | A | A | A | 25 |
| 100% - 40% | 92VAC | B | B | B | B | 10 |
| 100% - 0% | 0VAC | A | A | A | A | 1 |
| 100% - 0% | 0VAC | A | A | A | A | 0.5 |

| 100Vac | | | | | | |
|---------------|-------|-------------|-----|------|------|---------------------|
| Input Voltage | | Phase Angle | | | | Mains Cycles (50Hz) |
| | | 0° | 90° | 180° | 270° | |
| 100% - 80% | 80VAC | B | B | B | B | 250 |
| 100% - 70% | 70VAC | B | B | B | B | 25 |
| 100% - 40% | 40VAC | B | B | B | B | 10 |
| 100% - 0% | 0VAC | A | A | A | A | 1 |
| 100% - 0% | 0VAC | A | A | A | A | 0.5 |

| Voltage Interruptions Test Results | | | | | | |
|------------------------------------|------|------|------|----|-----|-----|
| Mains Cycles | 5 | 10 | 25 | 50 | 100 | 250 |
| 100% - 0% | 0.1s | 0.2s | 0.5s | 1s | 2s | 5s |
| 230VAC | B | B | B | B | B | B |
| 100VAC | B | B | B | B | B | B |

Conclusion:

Test Result were evaluated in relation to the Customer Specification CS-240PSM184.doc and the EUT was considered to have PASSED the tests.

PASS

Environmental conditions

Temperature: 15-30°C

Humidity: 30-60%

Air Pressure: 860-1060 hPa

Environmental conditions during the test:

kept

not kept

8. Conducted RF Immunity Test at AC Mains Terminals

Equipment under Test: TCL 240-124
EUT Serial No.: 31319786161
Customer Spec: CS-240PSM184.doc
Date: 04/11/2013
Standard: IEC61000-6-2: 2005 referring to IEC 61000-4-6:2004

Notes:

- EUT tested under normal operating conditions of 230V 50Hz input at full load (24V/10A Resistive).
- Test carried out using test generator “EM Test CWS 500N”, Coupling/Decoupling network “EM Test CDN M2/M3”, an attenuator “EM Test ATT6/75” and measurement instrument “Agilent 34410A”
- Unit tested to IEC61000-4-6 test level 3

8.1. Test Setup


Test Equipment Settings:

| Frq. start [MHz] | Level start [V] | Frq. stop [MHz] | Level stop [V] | Frq. step | td [s] | tp [s] | Modulation |
|------------------|-----------------|-----------------|----------------|-----------|--------|--------|-------------|
| 0.150 | 10.0 | 80.000 | 10.0 | 1.0 % | 0.5 | 0.0 | AM 1kHz 80% |

Test Setup:



8.2. Conducted RF Immunity Test Results



Conclusion:

Meets Classification A (Ref. Section 9, IEC 61000-4-3)

Test Results were evaluated in relation to the Customer Specification

CS-240PSM184.doc and the output did not change by more than +/-120mV therefore EUT was considered to have PASSED the tests.

PASS

Environmental conditions

Temperature: 15-30°C

Humidity: 30-60%

Air Pressure: 860-1060 hPa

Environmental conditions during the test:

kept

not kept

9. Conducted RF Immunity Test at DC Output Terminals

Equipment under Test: TCL 240-124
EUT Serial No.: 31319786161
Customer Spec: CS-240PSM184.doc
Date: 04/11/2013
Standard: IEC61000-6-2: 2005 referring to IEC 61000-4-6:2004

Notes:


- EUT tested under normal operating conditions of 230V 50Hz input at full load (24V/10A Resistive).
- Test carried out using test generator “EM Test CWS 500N”, Coupling/Decoupling network “EM Test CDN M2/M3”, an attenuator “EM Test ATT6/75”, measurement instrument “Agilent 34410A” and FCC-801-M2-50A Coupling/Decoupling network.
- Unit tested to IEC61000-4-6 test level 3

9.1. Test Setup:


Test Equipment Settings:

| Frq. start [MHz] | Level start [V] | Frq. stop [MHz] | Level stop [V] | Frq. step | td [s] | tp [s] | Modulation |
|------------------|-----------------|-----------------|----------------|-----------|--------|--------|-------------|
| 0.150 | 10.0 | 80.000 | 10.0 | 1.0 % | 0.5 | 0.0 | AM 1kHz 80% |

Test Setup:



9.2. Conducted RF Immunity Test Results



Conclusion:

Meets Classification A (Ref. Section 9, IEC 61000-4-3)

Test Results were evaluated in relation to the Customer Specification

CS-240PSM184.doc and the output did not change by more than +/-120mV therefore the EUT was considered to have PASSED the tests.

PASS

Environmental conditions

Temperature: 15-30°C

Humidity: 30-60%

Air Pressure: 860-1060 hPa

Environmental conditions during the test:

kept

not kept

10. Radiated RF Immunity Test

Equipment under Test: TCL 240-124
EUT Serial No.: 31319786161
Customer Spec: CS-240PSM184.doc
Date: 04/11/2013
Standard: IEC61000-6-2: 2005 referring to IEC61000-4-3: 2004

Notes:

- EUT tested under normal operating conditions of 230V 50Hz input at full load (24V/10A Resistive).
- Test carried out using test generator “EM Test CWS 500N”, Antenna BicoLOG 30100 X and Digitizing Multi Meter “Agilent 34405A”
- Measurement was carried out in a shielded room
- The input power port of the EUT was connected to mains via a 1.5m 3-core cable
- The output power port of the EUT was connected to the resistor bank via 1.5m long single core wires –wire size 14AWG

10.1. Test Setup


Test Equipment Settings:

| Frq. start [MHz] | Level start [V] | Frq. stop [MHz] | Level stop [V] | Frq. step | td [s] |
|---------------------|--------------------|--------------------|-------------------|-----------|-----------|
| 80.0 | 10.0 | 1000.0 | 10.0 | 1.0 % | 1 |

Test Setup:



10.2. Radiated RF Immunity Test Results



Conclusion:

Meets Classification A (Ref. Section 9, IEC 61000-4-3)

Test Results were evaluated in relation to the Customer Specification

CS-240PSM184.doc and the output did not change by more than $\pm 120\text{mV}$ therefore the EUT was considered to have PASSED the tests.

PASS

Environmental conditions

Temperature: 15-30°C

Humidity: 30-60%

Air Pressure: 860-1060 hPa

Environmental conditions during the test: kept not kept

11. Power Frequency Magnetic Field Immunity Test

Equipment under Test: TCL 240-124
EUT Serial No.: 31319786289
Customer Spec: CS-240PSM184.doc
Date: 06/08/2013
Standard: IEC61000-6-2: 2005 referring to IEC61000-4-8: 2001


Notes:

- EUT tested under normal operating conditions of 230V 50Hz input at full load (24V/10A Resistive).
- Test carried out using test generator “Chroma Programmable AC Source”, “1meter x 1meter 100 turn Induction Coil” and measurement instrument “Agilent 34405A”
- Unit only required to meet test level 4 but tested to IEC61000-4-8 test levels 5



11.1. Test Setup

Test Equipment Settings:

| Test generator settings | | | |
|-------------------------|--|-------------------------------|----------------------------|
| Frequency | AC Current through Induction Coil (Arms) | Magnetic Field Strength (A/m) | Applied Field duration [s] |
| 50Hz | 1 | 100 | Continuous |
| 60Hz | 1 | 100 | Continuous |
| 50Hz | 10 | 1000 | 3 |
| 60Hz | 10 | 1000 | 3 |



11.2. Power Frequency Magnetic Field Immunity Test Results



Conclusion:

Meets Classification A (Ref. Section 9, IEC 61000-4-8)

Test Results were evaluated in relation to the Customer Specification CS-240PSM184.doc and the EUT was considered to have PASSED the tests.

PASS

Environmental conditions

Temperature: 15-30°C

Humidity: 30-60%

Air Pressure: 860-1060 hPa

Environmental conditions during the test:

kept

not kept


12. Voltage Sag Immunity Test (Semi F47)

Equipment under Test: TCL 240-124
EUT Serial No.: 313119786161
Customer Spec: CS-240PSM184.doc
Date: 04/11/2013
Standard: SEMI F47-0706

Notes:

- EUT tested under operating conditions of 240V/100V 50Hz input at full load (11.86V/3.86A Resistive).
- Test carried out using test generator using Voltage Sag Generator: Schaffner NSG1003: Dropout and Variation Simulator and Oscilloscope Tektronix: TDS2014C

12.1. Test Setup



12.2. Voltage Sag Immunity test Results (Semi F47)

Input Voltage = 208VAC, Output = 24.09V, 10.0A

| Voltage Sag | Duration | Duration | Output Voltage | % delta of nominal output voltage | Semi F47 | Criteria |
|-------------|----------|----------|----------------|-----------------------------------|----------|----------|
| [V] | [s] | [cycles] | [V] | DUT 50Hz [%] | [%] | [Class] |
| 187.2 | 20 | 1000 | 24.09 | 0.0 | 90 | A |
| 187.2 | 10 | 500 | 24.08 | 0.0 | 90 | A |
| 166.4 | 10 | 500 | 24.08 | 0.0 | 80 | A |
| 166.4 | 1 | 50 | 24.08 | 0.1 | 80 | A |
| 166.4 | 0.5 | 25 | 24.07 | 0.1 | 80 | A |
| 145.6 | 0.5 | 25 | 0.01 | 100.0 | 70 | C |
| 145.6 | 0.5 | 10 | 0.07 | 99.7 | 70 | C |
| 104 | 0.2 | 10 | 0.08 | 99.7 | 50 | C |
| 104 | 0.02 | 1 | 24.06 | 0.1 | 50 | A |
| 0 | 0.02 | 1 | 24.06 | 0.1 | 0 | A |




Figure 1: TCL 240-124 / 0-1000 cycles




Figure 2: TCL 240-124 / 0-100 cycles

Input Voltage = 100VAC, Output = 24.09V, 10.0A

| Voltage Sag | Duration | Duration | Output Voltage | % delta of nominal output voltage | Semi F47 | Criteria |
|-------------|----------|----------|----------------|-----------------------------------|----------|----------|
| [V] | [s] | [cycles] | [V] | DUT 50Hz [%] | [%] | [Class] |
| 90 | 20 | 1000 | 24.06 | 0.1 | 90 | A |
| 90 | 10 | 500 | 24.05 | 0.1 | 90 | A |
| 80 | 10 | 500 | 1.42 | 94.1 | 80 | C |
| 80 | 1 | 50 | 1.45 | 94.0 | 80 | C |
| 80 | 0.5 | 25 | 1.45 | 94.0 | 80 | C |
| 70 | 0.5 | 25 | 0.00 | 100.0 | 70 | C |
| 70 | 0.5 | 10 | 0.07 | 99.7 | 70 | C |
| 50 | 0.2 | 10 | 0.07 | 99.7 | 50 | C |
| 50 | 0.02 | 1 | 24.05 | 0.2 | 50 | A |
| 0 | 0.02 | 1 | 24.05 | 0.2 | 0 | A |




Figure 3: TCL 240-124 / 0-1000 cycles




Figure 4: TCL 240-124 / 0-100 cycles

Conclusion:

Meets Classification B (Ref. SEMI F47-0706)

Test Results were evaluated in relation to the Customer Specification CS-020PSM184.doc and the EUT was considered to have PASSED the tests.

Environmental conditions

Temperature: 15-30°C

Humidity: 30-60%

Air Pressure: 860-1060 hPa

Environmental conditions during the test:

kept

not kept

13. Summary

| Regulation | Class/Test Level | Result | Comments |
|---|--|--------|----------|
| IEC61000-6-3: 2006 + CISPR 16-1-2: 2003 + CISPR 16-2-3: 2003 | | | |
| Conducted Input (0.15-30MHz) | Class B | PASS | |
| Conducted Output (0.15-30MHz) | Class B | n/a | |
| Radiated (30-300MHz) | Class B | PASS | |
| IEC61000-6-3: 2011 + IEC 61000-3-2: 2005 | | | |
| Harmonic Current Emissions Measurement at Mains Terminal | Class A | PASS | |
| IEC61000-6-2: 2005 + IEC 61000-4-2:2005 | | | |
| Electrostatic Discharge | | | |
| - Air Discharge | +/- 2/8kV (Class B) | PASS | |
| - Contact Discharge | +/- 2/4kV (Class B) | PASS | |
| IEC61000-6-2: 2005 + IEC 61000-4-5:2005 | | | |
| Surge | | | |
| - AC Power Ports | +/- 1kV (Class B) +VE to -VE | PASS | |
| - AC Power Ports | +/- 2kV (Class B) +VE to PE | PASS | |
| - AC Power Ports | +/- 2kV (Class B) -VE to PE | PASS | |
| IEC61000-6-2: 2005 + IEC 61000-4-4: 2004 | | | |
| Fast Transient (Burst) | | | |
| - AC & DC Power Ports | +/- 2kV (Class B) between all lines and ground plane | PASS | |
| - Signal Ports | +/- 1kV (Class B) between all lines and ground plane | PASS | |
| IEC61000-6-2: 2005 + IEC61000-4-6:2004 | | | |
| Conducted Input RF Immunity | Level III 10V (Class A) | PASS | |
| Conducted Output RF Immunity | Level III 10V (Class A) | PASS | |
| Signal Ports RF Immunity | Level III 10V (Class A) | PASS | |
| IEC61000-6-2: 2005 + IEC61000-4-3:2004 | | | |
| Radiated RF Immunity | Level III 10V (Class A) | PASS | |
| IEC61000-6-2: 2005 + IEC61000-4-8: 2001 | | | |
| Power Frequency Magnetic Field Immunity | Level 5 (Class A) | PASS | |

| | | | |
|---|--------------------|------|--|
| IEC61000-6-2:2005 + IEC 61000-4-11:2004 | | | |
| Voltage Dips | | | |
| -AC Supply (240VAC and 100VAC) | 100%-0% (Class B) | PASS | |
| | 100%-40% (Class C) | PASS | |
| | 100%-70% (Class C) | PASS | |
| | 100%-80% (Class C) | PASS | |
| Short Interruptions (100%-0% for: 0.1s, 0.2s, 0.5s, 1s, 2s and 5s) | 100%-0% (Class C) | PASS | |
| SEMI F47-0706 | | | |
| Semi F47 Voltage SAG Immunity | | | |
| -AC Supply (208VAC and 100VAC) | (Class B) | PASS | |
| IEC61000-6-2:2005 + IEC 61000-4-11:2004 | | | |
| Voltage Dips | | | |
| DC Supply (240VDC and 100VDC) | 100%-70% (Class B) | PASS | |
| | 100%-40% (Class B) | PASS | |
| Short Interruptions (100%-0% for: 1mS, 3mS, 10mS, 30mS, 100mS, 300mS, 1S) | 100%-0% (Class B) | PASS | |

14. List of Equipment Used:

| Description | Model No. | Manufacturer | Serial No. |
|-----------------------------|-----------------|-------------------|-----------------|
| EMC Analyzer | E7402A | Agilent | MY45119210 |
| LISN 1 | PMM L2-16 | PMM | 1230L00301 |
| LISN 2 | FCC-801-M2-50A | FCC | 3035 |
| LISN 3 | NSLK 8127 | Schwarzbeck | 8127683 |
| RF Current Probe | F-33-1 | FCC | 759 |
| Transient Limiter | 11947A | Agilent | 3107A03645 |
| Precision Power Meter | LMG95 | Zimmer | 10790709 |
| ESD Gun | SESD 200 | Schloder | 142261 |
| Surge Generator | PSURGE 4010 | Haefely | 583 334-63 |
| Burst generator | PEFT 4010 | Haefely | 080 981-08 |
| Coupling Capacitor | IP4A | Haefely | 171241 |
| Electronic Load | ELA 500 | Zentro-Elektrik | 63145803 |
| High Power Resistors | n/a | n/a | n/a |
| Multimeter | 34405A | Agilent | TW46290007 |
| Multimeter | 34405A | Agilent | TW46290015 |
| Multimeter | 34410A | Agilent | MY47012359 |
| Multimeter | 1906 | TTI | n/a |
| High frequency generator | CWS 500N | EM Test | V0847104427 |
| Coupling/Decoupling Network | CDN M2/M3 | EM Test | 1108-34 |
| Attenuator | ATT6/75 | EM Test | 1107-53 |
| Oscilloscope | TDS1002 | Tektronix | C016388 |
| Oscilloscope | TDS2014C | Tektronix | C010602 |
| Programmable AC Source | 61604 | Chroma | ABR000000672 |
| DC power supply | SM 7020 - D | Delta electronika | 014604000011 |
| DC power supply | SM 7020 - D | Delta electronika | 014604000024 |
| Pulse Generator | 33220A | AGILENT | MY44044002 |
| Biconical Antenna | BicoLOG 30100 X | AARONIA | 79479 |
| Cables | Type | Length | Comments |
| Mains Supply Cable | 3-wire | 1m | Unshielded |
| Mains Supply Cable | 3-wire | 1.5m | Unshielded |
| DC Lines Cable | 2-wire | 1m | Unshielded |
| DC Lines Cable | 2-wire | 1.5m | Unshielded |