

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Optional modules for building-in (DIN RAIL)

Name and address of the applicant

Traco Power Solutions Ltd.
Whitemill Industrial Estate Wexford, White Mill Road,
Y35 YH66, Ireland

Name and address of the manufacturer

Traco Power Solutions Ltd.
Whitemill Industrial Estate Wexford, White Mill Road,
Y35 YH66, Ireland

Name and address of the factory

Traco Power Solutions Ltd.
Whitemill Industrial Estate Wexford, White Mill Road,
Y35 YH66, Ireland*Note: When more than one factory, please report on page 2*☐ Additional Information on page 2

Ratings and principal characteristics

See page 2

Trademark (if any)

TRACO POWER

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See page 2


Additional information (if necessary may also
be reported on page 2)Unit also complies with EN 60950-1 :2006 + A1:2010 +
A2:2013 + A11:2009 + A12:2011☒ Additional Information on page 2A sample of the product was tested and found
to be in conformity withIEC 60950-1:2005 (Second Edition) + A1:2009 +
A2:2013As shown in the Test Report Ref. No. which
forms part of this CertificateT232-0044/18 issued by laboratory SIQ Testing and
Certification GmbH

This CB Test Certificate is issued by the National Certification Body

SIQ Ljubljana, Tržaška cesta 2, SI-1000 Ljubljana, Slovenia
T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si

Date: 2018-12-05

Signature: Bojan Pečavar



Ratings and principal characteristics:

Model	Input		Output	
	Voltage [V d.c.]	Current [A]	Voltage [V d.c.]	Current [A]
TSP-BCM12	DC-IN: 12 BATT-IN: 12	12,0	12	12,0
TSP-BCM24	DC-IN: 24 BATT-IN: 24	15,0	24	15,0
TSP-BCM48	DC-IN: 48 BATT-IN: 48	6,4	48	6,4
TSP-BCM24A	DC-IN: 24 BATT-IN: 24	25,0	24	25,0
TSP-BCM48A	DC-IN: 48 BATT-IN: 48	11,0	48	11,0
TSP-BFM24	24-28	Max. 25,0	24-28	Max. 25,0
TSP-REM360	Input1: 24 Input2: 24	15,0	24	15,0
TSP-REM600	Input1: 24 Input2: 24	25,0	24	25,0
TSPC-DCM600	Input1: 24 Input2: 24	25,0	24	25,0
TSP-BCMU360	Input1: 24/48 Input2: 24/48 BATT-IN: 13,8	15,0/7,5 15,0/7,5 30,0	24/48 24/48 22,4/44,9	15,0/7,5 15,0/7,5 10,0/5,0

Model / Type Ref.:

TSP-BCM12, TSP-BCM24, TSP-BCM48, TSP-BCM24A, TSP-BCM48A, TSP-BFM24, TSP-REM360, TSP-REM600, TSPC-DCM600, TSP-BCMU360

Models can be additionally marked with xxaaaaa, where 'x' or 'a' can be any alphanumeric, blank or dash, no impact on safety.

Additional information (if necessary)

This CB Test Certificate supersedes previously issued CB Test Certificate No. SI-5380, dated 2016-05-17, due to update of test report.

Date: 2018-12-05

Signature: Bojan Pečavar

