

TRACOPOWER

Model: TIW 06-105

EMC – Test Report

EUT: TRACOPOWER Model: TIW 06-105

Serial No.:

Manufacturer No.: 006UWA181

Manufacturer: Convertec Ltd.
Whitemill Industrial Estate
Wexford
Republic of Ireland

Tester: Tomás O’ Brien, Convertec

Date: 23/12/2008

It should be noted, that combining two or more CE compliant finished appliances does not automatically produce a compliant system. The manufacturer of an apparatus or a fixed installation as defined in the “Guide for the EMC Directive 2004/108EC, 21. May 2007” is responsible for the EMC-compliance of the final apparatus.

Table of Contents:

1	Conducted Input Emissions Test	3
1.1	Test Setup	3
1.2	Conducted Input Emissions Results.....	4
2	Radiated Emissions Test	5
2.1	Test Setup	6
2.2	Radiated Emissions Results.....	7
3	Harmonic Current Emissions Test	8
3.1	Test Set-Up:.....	8
3.2	Harmonic Emissions Results.....	9
4	Electrostatic Discharge Test	10
4.1	ESD Results.....	10
5	Surge Test	11
5.1	Test Setup	11
5.2	Surge Results.....	12
6	Fast Transient Test (Burst)	13
6.1	Test Setup	13
6.2	Burst Results.....	14
7	Voltage Dips and Short Interruptions	15
7.1	Test Setup	16
7.2	Voltage Dips & Short Interruptions Results.....	16
8	Summary	17
9	List of Equipment Used:	18

1 Conducted Input Emissions Test

Equipment Under Test: TIW 06-105
EUT Serial No.: N/A
Customer Spec: CS-006UWA181.doc
Date: 23/12/2008
Standards: IEC61000-6-3: 2006 referring to CISPR 16-1-2: 2003

Notes:

- EUT tested under normal operating conditions of 230V 50Hz input at full load (5V/1A Resistive)
- Emissions measured using PMM 8000 analyzer and PMM LISN
- Tested to CISPR 16 -1-2:2003 Class B limits
- Transient limiter used to protect PMM 8000, with appropriate correction factors applied
- Tests carried out in a shielded room

1.1 Test Setup

Test Equipment Settings:


Start Freq.	Stop Freq.	Step	Pk Time	Qpk Time	Avg Time
150kHz	30MHz	5kHz	50ms	500ms	50ms

Test Setup:




1.2 Conducted Input Emissions Results

L1



L2



PASS

2 Radiated Emissions Test

Equipment Under Test: TIW 06-105
EUT Serial No.: N/A
Customer Spec: CS-006UWA181.doc
Date: 23/12/2008
Standards: IEC61000-6-3:2006 referring to CISPR 16-2-3:2003

For an apparatus to comply with EMC radiated emissions requirements as set down in CISPR 16-2-3, free field measurements need to be performed. A test method similar to that described in IEC61204-3 (for low-voltage power supplies) section 6.4.2 shall be used here instead of free field measurements. This test is designed to give a good indication of whether an EUT will pass free field measurements or not. The absorber clamp used in this method is replaced by a Fischer high frequency current probe (Model: F-33-1). The limits used are set by comparison with open field measurements and are compensated by 20dB per frequency decade. Two limit lines are indicated; Fis_a and Fis_b, and the results may be interpreted as follows:

- Below limit line Fis_b: Limits are kept
- Below limit line Fis_a: Limits probably kept
- Above limit line Fis_a: Limits most likely not kept

Final Compliance can only be established by free field measurements in accordance to the relevant standard applicable to the apparatus or enclosure in which the power supply is used

Notes:

- EUT tested under normal operating conditions of 230V 50Hz input at full load (5V/1A Resistive)
- Emissions measured using receiver "PMM 8000 plus EMI Test Signal Analyzer" and FCC RF current probe
- RF current probe kept a distance of 10cm from input/output
- Tests carried out in shielded room
- Tested to CISPR 16 -2-3:2003 Class B limits

2.1 Test Setup





Figure 1. Test set-up for measurement of disturbance power similar to IEC61204-3

Test Equipment Settings:


Start Freq.	Stop Freq.	Step	Pk Time
30MHz	300MHz	100kHz	10ms

Test Setup: The following shows the setup used for input lines, the setup used for the output lines is the same with the clamp on the output lines.




2.2 Radiated Emissions Results

Input Lines:



Output Lines:



PASS


3 Harmonic Current Emissions Test

Equipment Under Test: TIW 06-105
EUT Serial No.: N/A
Customer Spec: CS-006UWA181.doc
Date: 23/12/2008
Standard: IEC61000-6-3: 2006 referring to IEC 61000-3-2: 2005

Notes:

- EUT tested under normal operating conditions of 230V 50Hz input at full load (5V/1A Resistive)
- EUT powered by low-distortion AC Voltage Source, TTI AC-1000
- Harmonic Limits measured using LMG 95 Power Meter
- Tested to IEC61000-3-2 Table 1 Class A

3.1 Test Set-Up:



3.2 Harmonic Emissions Results

n	Harmonic Limit	Measured Values
3	2.3	0.036
5	1.14	0.033
7	0.77	0.030
9	0.4	0.026
11	0.33	0.021
13	0.21	0.016
15	0.15	0.012
17	0.1324	0.008
19	0.1184	0.007
21	0.1071	0.006
23	0.0978	0.006
25	0.09	0.006
27	0.0833	0.005
29	0.0776	0.004
31	0.0726	0.003
33	0.0682	0.003
35	0.0643	0.003
37	0.0608	0.003
39	0.0577	0.002

PASS

4 Electrostatic Discharge Test

Equipment Under Test: TIW 06-105
EUT Serial No.: N/A
Customer Spec: CS-006UWA181.doc
Date: 23/12/2008
Standard: IEC61000-6-2: 2005 referring to IEC 61000-4-2: 2000

Notes:

- As stated in the installation instructions at:
http://www.tracopower.com/products/tiw_inst.pdf

“ This power supply is designed for professional indoor systems. In operation the power supply must not be accessible. It may be installed and put into service by qualified personnel only.”
- And IEC 61000-4-2: 2000 section 8.3.1 states that:

“Unless stated otherwise in the generic, product-related or product-family standards, the static electricity discharges shall be applied only to those points and surfaces of the EUT which are accessible to persons during normal use. The following exclusions apply (i.e. discharges are not applied to those items):

c) Those points and surfaces of equipment which are no longer accessible after fixed installation or after following the instructions for use”

Therefore in accordance with IEC 61000-4-2: 2000 section 8.3.1 no ESD tests need to be carried out.

4.1 ESD Results

NOT APPLICABLE


5 Surge Test

Equipment Under Test: TIW 06-105
EUT Serial No.: N/A
Customer Spec: CS-006UWA181.doc
Date: 23/12/2008
Standard: IEC61000-6-2: 2005 referring to IEC 61000-4-5: 2005

Notes:

- EUT tested under normal operating conditions of 230V 50Hz input at full load (5V/1A Resistive)
- Used Haefely Surge generator PSURGE 4010
- Voltage test level: +/- 1kV Line-Line, +/- 2kV Line-Earth (installation class 3)
- No. of Surges per set: 5 tests Positive at 0, 90, 180, and 270 and 5 tests Negative at 0, 90, 180, and 270
- Interval Between Surges: 10s

5.1 Test Setup



5.2 Surge Results

	L to N	L to PE	N to PE
EUT: 006UWA181	PASS	PASS	PASS

Conclusion:

Meets Classification A (Ref. Section 9, IEC 61000-4-5)

Only Class B performance criteria are required as per Table 6, IEC 61204-3

PASS


6 Fast Transient Test (Burst)

Equipment Under Test: TIW 06-105
EUT Serial No.: N/A
Customer Spec: CS-006UWA181.doc
Date: 23/12/2008
Standard: IEC61000-6-2: 2005 referring to IEC 61000-4-4: 2004

Notes:

- EUT tested under normal operating conditions of 230V 50Hz input at full load (5V/1A Resistive)
- Units tested to IEC61000-4-4 test level 3
- Used Haefely Burst tester PEFT 4010
- Voltage test level: $\pm 2\text{Kv}$
- Burst Duration: 0.75ms
- Repetition rate: 100kHz
- Burst Period: 300ms
- Individual test time: 1 min
- Polarity: Positive and Negative

6.1 Test Setup



6.2 Burst Results

EUT: 006UWA181	L-G	N-G	PE-G	L,N-G	L,PE-G	N,PE-G	L,N,PE-G
Positive	PASS	PASS	PASS	PASS	PASS	PASS	PASS
Negative	PASS	PASS	PASS	PASS	PASS	PASS	PASS

Conclusion:

Meets Classification A (Ref. Section 9, IEC 61000-4-5)

Only Class B performance criteria are required as per Table 6, IEC 61204-3

PASS


7 Voltage Dips and Short Interruptions

Equipment Under Test: TIW 06-105
EUT Serial No.: N/A
Customer Spec: CS-006UWA181.doc
Date: 23/12/2008
Standard: IEC61000-6-2:2005 referring to IEC 61000-4-11:2004

Notes:

- EUT tested under normal operating conditions of 230V 50Hz input at full load (5V/1A Resistive)
- Test carried out using 2 Variacs and dropout simulator NSG 1003
- Tested according to class 3 IEC61000-4-11
- Units tested with highest and lowest nominal voltage (240V/110V) in accordance with IEC61000-4-11 section 5
- Interval between dropouts and short interruptions was 10s
- Phase angle was set to 0°, 90°, 180° and 270° for each voltage level tested
- Dropouts were tested from 100% -80% for 250 Mains cycles in accordance with IEC61000-4-11 table 2
- Dropouts were tested from 100% -70% for 25 Mains cycles in accordance with IEC61000-4-11 table 2
- Dropouts were tested from 100% -40% for 10 Mains cycles in accordance with IEC61000-4-11 table 2
- Dropouts were tested from 100% -0% for 1 Mains cycle in accordance with IEC61000-4-11 table 2
- 3 dropouts and 3 short interruptions were carried out per test
- Short interruptions tests were carried out at 100% to 0% for 0.1s, 0.2s, 0.5s, 1s, 2s, and 5s durations
- Short interruptions were done at worst case 0° phase angle

7.1 Test Setup



7.2 Voltage Dips & Short Interruptions Results

Voltage Dips

240VAC				
Phase Angle:	0	90	180	270
100%-0%	Class A	Class A	Class A	Class A
100%-40%	Class A	Class A	Class A	Class A
100%-70%	Class A	Class A	Class A	Class A
100%-80%	Class A	Class A	Class A	Class A
110VAC				
Phase Angle:	0	90	180	270
100%-0%	Class A	Class A	Class A	Class A
100%-40%	Class B	Class B	Class B	Class B
100%-70%	Class A	Class A	Class A	Class A
100%-80%	Class A	Class A	Class A	Class A

Short Interruptions

100%-0%	0.1s	0.2s	0.5s	1s	2s	5s
110VAC	Class B	Class B	Class B	Class B	Class B	Class B
240VAC	Class A	Class B	Class B	Class B	Class B	Class B

Conclusion:

- In accordance with Class B, IEC61000-4-11 section 9 (b)

PASS

8 Summary

Regulation	Class/Test Level	Result	Comments
IEC61000-6-3: 2006 + CISPR 16-1-2: 2003 + CISPR 16-2-3: 2003			
Conducted Input (0.15-30MHz)	Class B	PASS	
Radiated (30-300MHz)	Class B	PASS	
IEC61000-6-3: 2006 + IEC 61000-3-2: 2005			
Harmonic Current Emissions	Class A	PASS	
IEC61000-6-2: 2005 + IEC 61000-4-2: 2000			
EUT will be inaccessible to persons during normal use		NOT APPLICABLE	
IEC61000-6-2: 2005 + IEC 61000-4-5: 2005			
Surge			
-AC Supply	+/- 1kV (ClassB) L-N	PASS	
	+/- 2kV (ClassB) L-PE	PASS	
	+/- 2kV (ClassB) N-PE	PASS	
IEC61000-6-2: 2005 + IEC 61000-4-4: 2004			
Fast Transient (Burst)			
-AC Supply	+/- 2kV (ClassB)	PASS	
	Between all lines		
IEC61000-6-2:2005 + IEC 61000-4-11:2004			
Voltage Dips			
-AC Supply	100% -0% (Class A)	PASS	
	100% -40% (Class B)	PASS	
	100% -70% (Class A)	PASS	
	100% -80% (Class A)	PASS	
Short Interruptions (100%-0% for: 0.1s, 0.2s, 0.5s, 1s, 2s and 5s)	Class B	PASS	

9 List of Equipment Used:

Description	Model No.	Manufacturer	Serial No.
Test Signal Analyzer	PMM 8000PLUS	PMM	0100J91001
LISN 1	PMM L2-16	PMM	1230L00301
LISN 2	FCC-801-M2-50A	FCC	3035
RF Current Probe	F-33-1	FCC	759
Transient Limiter	11947A	Agilent	3107A03645
Precision Power Meter	LMG95	Zimmer	10790709
Low-Distortion AC Source	AC1000	Thurlby Thandar Instruments	151093
ESD Gun	SESD 200	Schloder	142261
Surge Generator	PSURGE 4010	Haefely	583 334-63
Burst generator	PEFT 4010	Haefely	080 981-08
Dropout & Variation Simulator	NSG 1003	Schaffner	106
Electronic Load	6314/63106	Chroma	63145803
High Power Resistors	n/a	n/a	n/a
Multimeter	M2008	BBC	M24119181
Multimeter	Hit 23S	Metra	NE4126
Oscilloscope	TDS1002	Tektronix	C016388
Cables	Type	Length	Comments
Mains Supply Cable	3-wire	1m	Unshielded
DC Lines Cable	2-wire	1m	Unshielded