

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE**CERTIFICAT D'ESSAI OC**

Product
Produit

Switch Mode Power Supply for building-in (DIN RAIL)

Name and address of the applicant
Nom et adresse du demandeur

Traco Power Solutions Ltd.
Whitemill Industrial Estate Wexford, White Mill Road, Y35
YH66, Ireland

Name and address of the manufacturer
Nom et adresse du fabricant

Traco Power Solutions Ltd.
Whitemill Industrial Estate Wexford, White Mill Road, Y35
YH66, Ireland

Name and address of the factory
Nom et adresse de l'usine

Traco Power Solutions Ltd.
Whitemill Industrial Estate Wexford, White Mill Road, Y35
YH66, Ireland

Note: When more than one factory, please report on page 2
Note: Lorsque il y a plus d'une usine, veuillez utiliser la 2^{ème} page

☐ Additional Information on page 2

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

See page 2

Trademark (if any)
Marque de fabrique (si elle existe)

TRACO POWER

Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais constructeur

/

Model / Type Ref.
Ref. De type

See page 2

Additional information (if necessary may also be reported
on page 2)

Unit also complies with EN 60950-1:2006 + A1:2010 +
A2:2013 + A11:2009 + A12:2011

Les informations complémentaires (si nécessaire, peuvent
être indiqués sur la 2^{ème} page

☒ Additional Information on page 2

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC 60950-1:2005 (Second Edition) + A1:2009 + A2:2013

As shown in the Test Report Ref. No. which forms
part of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

T223-0334/16


This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



SIQ Ljubljana
Tržaška cesta 2, SI-1000 Ljubljana, Slovenia
T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si
Product Certification Body is accredited by Slovenian Accreditation, Reg. No.: CP-001

Date: 2016-05-10

Signature: Bojan Pečavar



Model/Type reference : TRACO POWER

Manufacturer

Model reference

Model reference

TSP180-124WRxxxx

120PSP184xxxx

TSP360-124WRxxxx

240PSP184xxxx

TSP600-124WRxxxx

480PSP184xxxx

* Each model can be alternatively marked with a suffix xxxx for non safety relevant changes. No impact on safety.

Ratings..... : Input:

TSP180-124WR: 115/230/400-500 Vac; 4,0/2,0/1,0 A; 50/60 Hz

TSP360-124WR: 115/230/400-500 Vac; 6,0/3,0/1,5 A; 50/60 Hz

TSP600-124WR: 115/230/400-500 Vac; 10,0/5,0/3,0 A; 50/60 Hz

Output:

TSP180-124WR: 24 Vdc; 7,5 A

TSP360-124WR: 24 Vdc; 15,0 A

TSP600-124WR: 24 Vdc; 25,0 A

Outputs are adjustable from 24-28 Vdc

Additional information (if necessary)**Information complémentaire (si nécessaire)**

This CB Test Certificate supersedes previously issued CB Test Certificate No. SI-3027 B2, dated 2011-08-31, due to update of the test report.

Date: 2016-05-10

Signature: Bojan Pečavar

