



Ref. Certif. No.

**SI-5460**

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC

## CB TEST CERTIFICATE

## CERTIFICAT D'ESSAI OC

Product  
Produit

Power supply for built-in use (DIN rail)

Name and address of the applicant  
Nom et adresse du demandeur

Traco Power Solutions Ltd.  
Whitemill Industrial Estate Wexford, White Mill Road,  
Y35 YH66, Ireland

Name and address of the manufacturer  
Nom et adresse du fabricant

Traco Power Solutions Ltd.  
Whitemill Industrial Estate Wexford, White Mill Road,  
Y35 YH66, Ireland

Name and address of the factory  
Nom et adresse de l'usine

Traco Power Solutions Ltd.  
Whitemill Industrial Estate Wexford, White Mill Road,  
Y35 YH66, Ireland

*Note: When more than one factory, please report on page 2*  
*Note: Lorsque il y a plus d'une usine, veuillez utiliser la 2ème page*

☐ Additional Information on page 2

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

See page 2

Trademark (if any)  
Marque de fabrique (si elle existe)

TRACO POWER

Type of Manufacturer's Testing Laboratories used  
Type de programme du laboratoire d'essais constructeur

/

Model / Type Ref.  
Ref. De type

TSPxxx-124-3PACxxx (see page 2)

Additional information (if necessary may also be reported  
on page 2)

Les informations complémentaires (si nécessaire, peuvent  
être indiqués sur la 2<sup>ème</sup> page

Unit also complies with EN 60950-1:2006 + A1:2010 +  
A2:2013 + A11:2009 + A12:2011

☐ Additional Information on page 2

A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

IEC 60950-1:2005 (Second Edition) + A1:2009 + A2:2013

As shown in the Test Report Ref. No. which forms  
part of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

T221-0042/16 issued by laboratory SIQ Testing and  
Certification GmbH

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



SIQ Ljubljana  
Tržaška cesta 2, SI-1000 Ljubljana, Slovenia  
T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si

Date: 2016-06-28

Signature: Bojan Pečavar

<b>Model/Type reference.....:</b>	TRACO POWER	Manufacturer
	Model reference	Model reference
	TSP 240-124-3PAC400	240PRL194A
	TSP 240-124-3PAC500	240PRL194B
	TSP 480-124-3PAC400	480PRL194A
	TSP 480-124-3PAC500	480PRL194B
	TSP 960-124-3PAC400	960PRL194A
	TSP 960-124-3PAC500	960PRL194B

<b>Ratings..... :</b>	<u>Model</u>	<u>Input</u>	<u>Output</u>
	TSP240-124-3PAC400	3 x 400 V; 50/60 Hz; 0,50 A	24 Vdc; 10 A
	TSP240-124-3PAC500	3 x 500 V; 50/60 Hz; 0,40 A	24 Vdc; 10 A
	TSP480-124-3PAC400	3 x 400 V; 50/60 Hz; 0,96 A	24 Vdc; 20 A
	TSP480-124-3PAC500	3 x 500 V; 50/60 Hz; 0,75 A	24 Vdc; 20 A
	TSP960-124-3PAC400	3 x 400 V; 50/60 Hz; 1,9 A	24 Vdc; 40 A
	TSP960-124-3PAC500	3 x 500 V; 50/60 Hz; 1,5 A	24 Vdc; 40 A

Additional information (if necessary)  
Information complémentaire (si nécessaire)

Date: 2016-06-28

Signature: Bojan Pečavar

